



# Memorandum

**TO:** HONORABLE MAYOR  
AND CITY COUNCIL

**FROM:** Kerrie Romanow  
Rosalynn Hughey

**SUBJECT:** SEE BELOW

**DATE:** May 26, 2020

Approved

Date

5/28/2020

**SUBJECT: DIRECTION ON PROPOSED EXTENSION OF NATURAL GAS INFRASTRUCTURE PROHIBITION ORDINANCE AND CLERICAL AMENDMENTS TO THE SAN JOSE MUNICIPAL CODE RELATED TO MIXED FUEL BUILDINGS**

## RECOMMENDATION

- (a) Accept the update on staff analysis as to whether or not the City should require electrification for buildings over three stories.
- (b) Direct City Manager to return to Council in September 2020 with a natural gas prohibition ordinance amendment to be implemented on June 1, 2021 and covering all building types:
  - (1) Including mid-rise and high-rise multifamily buildings, as supported by cost effectiveness studies, and
  - (2) Exempting restaurants, hospitals, industrial, and manufacturing facilities.
- (c) Approve an ordinance amending Section 24.12.300 of Chapter 24.12 of Title 24 of the San José Municipal Code Related to the Reach Code Requirements for Mixed Fuel Buildings to make clerical amendments.
- (d) Authorize the City Manager to submit an amended reach code submittal package to the California Energy Commission for its approval as required by law.

## OUTCOME

Approval of these recommendations will correct citations in the current Reach Code and direct staff to proceed on bringing forward an Ordinance with a natural gas infrastructure prohibition extending to all new construction, as supported by cost-effectiveness studies, which will further community-wide progress on meeting the goals of the following Climate Smart San José strategies:

- Strategy 1.1: Transition to a renewable energy future
- Strategy 2.2: Make homes efficient and affordable for our residents
- Strategy 3.2: Improve our commercial building stock

## **EXECUTIVE SUMMARY**

The Climate Smart San José plan (Climate Smart) was approved by City Council in February 2018 and includes goals and milestones, such as all new zero net energy buildings and carbon-free power, to ensure San José can reduce greenhouse gas (GHG) emissions. The City has made progress towards its Climate Smart goals by passing its building reach code ordinances incentivizing all-electric building across all building types and prohibiting natural gas infrastructure thereby requiring all-electric residential and low-rise multi-family buildings up to three stories.

Along with the passage of these ordinances, staff was directed to return to Council with an analysis as to whether the City should require electrification for wood-framed buildings up to seven stories. Staff worked with the New Buildings Institute, Inc. to host a Building Electrification Experts' Roundtable (Experts' Roundtable). New Buildings Institute, Inc. drafted its *Technical Analysis on Extending San José's All-Electric Requirement* (Attachment A) which was informed by input from: the Experts' Roundtable, the State's recently released preliminary findings for its *Cost Effectiveness Study for Mid-rise Buildings*, discussions with stakeholders, related webinar presentations and conferences, and supply chain interviews. Based on the report's findings and experience working with the construction industry, staff recommends proceeding with the development of an amendment to the City's natural gas infrastructure prohibition ordinance in order to extend it to all buildings, as supported by cost effectiveness studies, with an exemption for restaurants, hospitals, industrial, and manufacturing facilities.

## **BACKGROUND**

Approved by City Council in February 2018, the Climate Smart plan includes the following goals and milestones to ensure San José can reduce its GHG emissions on target:

- Ensuring all new residential (by 2020) and commercial (by 2030) buildings are zero net energy.
- Providing 100 percent carbon-free base power from San José Clean Energy by 2021.
- Reimagining the "Good Life 2.0," that harnesses the benefits of sustainable actions and improves our quality of life.

In February 2019, City Council approved the City's participation in the American Cities Climate Challenge, which included a support package of in-kind services through organizations like the Natural Resources Defense Council, Inc. and New Buildings Institute, Inc., valued at \$2.5 million through 2020, and the commitment to pursue adoption of a reach code for Electric Vehicle and solar-readiness in new residential and commercial construction. The City Council also approved a resolution declaring a Climate Emergency on September 17, 2019 which included the commitment to pursue a goal of prohibiting natural gas in new construction projects citywide by January 1, 2023.

The City has made significant progress towards achieving its Climate Smart goals through fulfilling these commitments. On September 17, 2019, City Council approved the City's building Reach Code, incentivizing all-electric buildings and requiring electric vehicle charging infrastructure and solar readiness requirements exceeding those of the 2019 California Green Building Standards Title 24, Part 11 and 2019 California Energy Efficiency Standards Code Title 24, Part 6 (Title 24). In taking that action, Council included direction for staff to return to Council in October 2019 with an ordinance prohibiting natural gas infrastructure in new detached accessory dwelling units, single-family, and low-rise multi-family building (three stories and under) starting January 1, 2020, along with the Reach Code. Staff was directed to return to Council with an analysis as to whether the City should require electrification for wood-framed buildings up to seven stories. On October 29, 2019, City Council approved a natural gas infrastructure prohibition covering single-family, accessory dwelling units, and low-rise multifamily buildings up to three stories, which supplements the Reach Code.

Currently, 17 California jurisdictions, including San José, Mountain View, and San Mateo County, have adopted some form of building codes requiring fully all-electric buildings. See Attachment B for a summary of the components of adopted building codes, which require partial or fully all-electric buildings, from 22 jurisdictions across California.

## **ANALYSIS**

In order to inform staff's analysis on a potential extension of the City's natural gas infrastructure prohibition ordinance, in December 2019, the City hosted a three-hour Expert's Roundtable convening industry stakeholders from various sectors including building construction and development, real estate, affordable housing, architecture, engineering, industry associations, manufacturing, and more. See Attachment A, Appendix A, for a list of participating organizations.

The Experts' Roundtable brought in technical experts and industry stakeholders together to discuss and address some of challenges and propose solutions with all-electric new construction, with a particular focus on buildings over three stories. It featured presentations from leading electrification experts listed including Sean Armstrong, *Redwood Energy*, Hormoz Janssens, *Interface Engineering, Inc.*, and Nick Young, *Association for Energy Affordability*. A panel discussion followed the presentations with leading electrification experts sharing how to overcome some of the perceived barriers with all-electric design and construction. The latter part of the Experts' Roundtable involved a series of break-out discussions to cover and address some of the common concerns with all-electric new construction, including:

1. California Energy Commission and software modeling for heat pump water heater compliance;
2. Market readiness: what is needed to transition the market (i.e. workforce, product and demand);
3. Electrical capacity: transformer upgrades and sizing for electric vehicle charging infrastructure requirements;

4. Addressing heat pump water heater challenges in multi-family and mixed-use buildings of all sizes; and
5. Affordable housing and building electrification.

Participants identified the main challenges or problems from their perspective, with each of these topics, as well as potential solutions. Attachment C summarizes the discussion at each breakout session.

City staff worked with New Buildings Institute, Inc. to draft a technical report evaluating the feasibility of all-electric new construction (see Attachment A). The technical report uses several resources to inform its findings, including the Experts' Roundtable, the State's *Cost Effectiveness Study for Mid-rise Buildings*, discussions with stakeholders, webinar presentations and conferences (such as Steven Winter Associates, Inc., at the 2020 ASHRAE Winter Conference), and interviews conducted by Building Electrification Initiative. Since the technical report indicates that the structural material used in a building (e.g., wood framed, steel, concrete) and the height of the building (i.e. number of stories) does not have a substantial impact on the technical feasibility of an all-electric building, the report was not limited to up to seven-story wood-framed buildings but, instead, provided analysis relevant to any building over three stories.

The report considered three indicators to determine feasibility: technical, economic, and market. Technical feasibility considered all-electric building technology and systems (e.g., space heating, water heating) and the impact of all-electric building design on onsite electrical infrastructure. Economic feasibility considered the cost effectiveness of all-electric new construction buildings as compared with mixed fuel. Market feasibility considered the availability of electric equipment and technology, the availability of design and construction expertise, and market acceptance of electric alternatives to gas equipment.

The report finds the design and construction of all-electric buildings to be technically feasible based on an assessment of the technology and individual equipment systems used in all-electric buildings. These systems include domestic hot water heating (both individual and central), space heating, cooking, clothes drying, and miscellaneous loads. The report also looks at electrical service and transformer capacity, both of which can be impacted with all-electric new construction. The report identifies common challenges and proposes design solutions with all-electric systems based on best practices. Most of the issues identified in the report can be addressed with early planning, best electric building practices, and thoughtful design.

The report evaluated cost effectiveness based on the California Statewide Codes and Standards' preliminary *Mid-Rise Residential New Construction Cost-Effectiveness Analysis* as presented in their March 11, 2020 webinar. That preliminary analysis found that all-electric mid-rise multifamily buildings can be cost-effective with appropriate design. In addition, since the market for certain types, such as centralized, heat pump water heaters is still nascent, costs are expected to come down as market adoption increases and manufacturers and installers achieve economies of scale. While the report notes that the cost-effectiveness study for new high-rise multifamily is

still under development, the Codes and Standards team indicated during the webinar that it is likely to show that this type of all-electric construction is also cost-effectiveness. Other mid- and high-rise building types were already deemed cost-effective under previous studies. The process loads of industrial/manufacturing facilities are not regulated by the Energy Code and therefore are not included in the cost effectiveness studies. The City exempted these facility types from the increased efficiency requirements for mixed-fuel buildings in the current Reach Code.

Market feasibility, including the availability of industry professionals with all-electric design expertise and consumer acceptance of all-electric equipment, may pose the biggest barrier to adoption. Since all-electric new construction is still at an early stage in the Bay Area, training and educational resources will help building professionals feel more comfortable and enable them to transition. Market perceptions of residential and commercial cooking remain a barrier to adoption. While using natural gas for cooking is more prevalent in the Northeast and West, electricity is still the most common fuel source for cooking in the U.S., particularly in the South. In California, there is a market preference for gas cooking by some consumers and commercial kitchen, as well as developer perception of market preferences for natural gas. These barriers can be addressed by shifting market perception and informing consumers about the negative health and environmental impacts of using natural gas in the home.

Based on the information that staff has been able to obtain to-date on the current status of other jurisdictions' all-electric building requirements, 17 of 22 California jurisdictions who adopted all-electric building requirement approaches did so with a whole-building approach. Many do not include or specifically exempt specific building types such as: hospitals/emergency centers (14 of 17); life science buildings (e.g. labs; 12 of 17); and restaurants (8 of 17). For those jurisdictions that required all-electric low- or high-rise residential buildings, three of fifteen exempted residential cooking appliances.

An expansion of the natural gas infrastructure prohibition would have a positive benefit on indoor environmental air quality. Natural gas stoves can generate unhealthy levels of indoor air pollutants, such as carbon monoxide and formaldehyde, especially if not properly ventilated. Expanding the current prohibition would also have a significant positive impact on future GHG emissions. According the City's latest five-year development forecast, San José can conservatively expect an average of 2,375 new multi-family residences and 1.4 million square feet of commercial construction (excluding industrial buildings) per year between 2020 and 2023. The projected GHG emissions offset by an expansion of the natural gas infrastructure prohibition over the estimated 50-year lifecycle of these buildings is approximately 608,000 tons of CO<sub>2</sub>.

**Table 1. Years 2021-2023 Multifamily and Commercial Projected New Construction Development in San José and CO<sub>2</sub> Emissions Reduction Impact Over Building Lifetime**

Building Type	Sq. Ft.	CO <sub>2</sub> /Yr.	x	Units/ Yr. <sup>1</sup>	x	Years in Service	Total Tons of CO <sub>2</sub>
Multifamily	1,000	1 ton	x	2,375	x	50	356,250 tons
Commercial	100,000	120 tons	x	14	x	50	252,000 tons
							<b>608,250 tons</b>

Since the implementation of the City's existing reach code and natural gas infrastructure prohibition ordinances in January 2020, City staff have had a handful of inquiries from planned development projects. In most cases, staff was able to provide clarification and mitigate concerns related to balancing compliance with other potential issues such as increased costs or apply an exemption as warranted. The City is also able to request further one-on-one technical assistance for development projects through 2020 from a consultant, Association for Energy Affordability, via its American Cities Climate Challenge grant. Staff continues to monitor development issues for consideration of future City action (e.g. further outreach, messaging, trainings, or amendments).

Based on the technical report, staff's experience working with project development teams under the current ordinances, the GHG reduction benefits, and the current state of reach codes in California, staff recommends proceeding with the development of an amendment of the natural gas infrastructure prohibition ordinance in order to extend it to all buildings, as supported by cost-effectiveness studies, with an exemption for restaurants, hospitals, industrial, and manufacturing facilities. Staff would be able to return to Council with an amended ordinance as by September 2020 with the intention of having a June 1, 2021 implementation date. While the reach code and all-electric components were informed by an extensive stakeholder outreach process, staff will conduct two additional stakeholder meetings to review the extension of the natural gas infrastructure prohibition prior to returning to Council. In addition, in order to continue to address barriers identified in the technical report (e.g. market awareness), City staff intends to continue with its all-electric building assistance and outreach efforts including informational handouts, website updates, trainings, participation in a statewide consumer education campaign led by the Building Decarbonization Coalition, and technical assistance, as resources allow.

In addition, staff recommends clerical changes to the existing Reach Code by correcting citations (see Attachment D). These are not substantive changes to the Code, and therefore, the changes will not impact previously adopted findings or cost effectiveness.

<sup>1</sup> City of San José. (2020, February). Development Activity Highlights and Five-Year Forecast (2021-2025). Table 2, page 5. Retrieved from <https://www.sanjoseca.gov/home/showdocument?id=54320>

## **CONCLUSION**

All-electric construction is technologically feasible, although some market constraints remain. Expansion of the City's natural gas connection prohibition ordinance, beyond buildings taller than three stories in height, should be predicated on the Technical Analysis attached herein, the release of California Energy Commission cost-effectiveness studies for mid- and high-rise structures, and flexibility around market transition for certain types of building uses.

## **EVALUATION AND FOLLOW-UP**

Staff will return to Council in September 2020 with an amended natural gas prohibition ordinance. Staff will track data associated with the compliance of the City's reach code and natural gas infrastructure prohibition and report back to Council in May 2021 and annually thereafter, per City Council direction at the September 17, 2019 City Council meeting. Staff will provide progress updates to Transportation and Environment Committee and City Council on Climate Smart San José activities on a semi-annual basis.

## **CLIMATE SMART SAN JOSÉ**

The recommendation in the memo aligns with one or more Climate Smart San José energy water or mobility goals:

- Strategy 1.1: Transition to a renewable energy future
- Strategy 2.2: Make homes efficient and affordable for our residents
- Strategy 3.2: Improve our commercial building stock

## **PUBLIC OUTREACH**

This memorandum will be posted on the City's website for the June 9, 2020 City Council meeting.

## **COORDINATION**

This memorandum has been coordinated with the City Attorney's Office, City Manager's Office, Community Energy Department, Housing Department, and Office of Economic Development.

HONORABLE MAYOR AND CITY COUNCIL

May 26, 2020

**Subject: Direction on Proposed Extension of Natural Gas Infrastructure Prohibition Ordinance and Clerical Amendments to the San José Municipal Code Related to Mixed Fuel Buildings**

Page 8

### **FISCAL/POLICY ALIGNMENT**

The recommendations align with the Climate Smart San José strategies and the City's Envision 2040 General Plan approved by City Council.

### **CEQA**

Not a Project, File No. PP19-067, Actions by Regulatory Agencies for Protection of the Environment.

/s/

ROSALYNN HUGHEY

Director, Planning, Building, and Code Enforcement

/s/

KERRIE ROMANOW

Director, Environmental Services

For questions, please contact Ken Davies, Deputy Director, at (408) 975-2587.

Attachments:

Attachment A – *Technical Analysis on Extending San José's All-Electric Requirement*

Attachment B – All-Electric Reach Codes by Jurisdiction

Attachment C – Summary of Building Electrification Experts' Roundtable Discussion

Attachment D – San José Reach Code Edits



# Technical Analysis on Extending San José's All-Electric Requirement

February 20, 2020

Prepared by:

Sean Denniston, Senior Project Manager



## Table of Contents

Executive Summary.....	3
Background .....	3
San José’s Climate Smart Goals.....	3
Adopted Reach Code and Natural Gas Infrastructure Prohibition .....	4
Scope of this Analysis.....	5
Sources.....	6
Feasibility & Approaches to All-Electric Buildings.....	6
Technical Feasibility .....	6
Water Heating.....	6
Individual Systems .....	8
Central Systems.....	9
Space Heating .....	12
Cooking .....	13
Clothes drying .....	13
Other Gas Loads.....	13
Impact on Electrical Infrastructure .....	14
Electrical Service and Transformer Capacity.....	14
Back-up Power Supply .....	15
Economic Feasibility.....	15
Market Feasibility.....	16
Residential Cooking.....	17
Commercial Cooking .....	18
Summary of Findings.....	18

## Executive Summary

The purpose of this report is to provide a technical evaluation of the feasibility of all-electric mid-and high-rise new construction buildings in order to inform the City's recommendations related to an extension of a natural gas infrastructure prohibition (i.e. all-electric building requirement) to new buildings over three stories. In partnership through the American Cities Climate Challenge, the City of San José ("City") worked with New Buildings Institute (NBI) as its technical partner to develop the City's adopted reach code and natural gas infrastructure prohibition ordinances. This report draws on NBI's expertise in building and policy design as well as several sources including: technical studies/reports, discussions with leading industry experts at a Building Electrification Experts' Roundtable ("Experts' Roundtable" or "Roundtable"), buildings conferences, webinars, and market research. The report evaluates and determines the feasibility of all-electric mid- and high-rise new construction based on three factors: 1) technical feasibility of all-electric equipment/systems, 2) cost effectiveness of all-electric new construction compared with mixed fuel, and 3) market feasibility which includes the availability of all-electric equipment, design expertise of building practitioners and market consumer preferences. The report concludes that the design and construction of all-electric buildings is technically feasible in mid-high-rise new construction, however, there are certain market challenges, including building practitioner awareness and training (particularly in designing for central water heating system in multifamily buildings and hotels) and perceived market preferences in California for gas cooking in residential and commercial applications (primarily restaurants) that may impact the transition toward all-electric new construction. A summary of findings can be found on pages 15-16 of this report.

## Background

### San José's Climate Smart Goals

San José's Climate Smart San José ("Climate Smart") goals call for reducing greenhouse gas (GHG) emissions by approximately 52% below 2010 by 2030. In order to achieve these goals, the City will need to reduce its GHG emissions from each of the six emission sectors, including residential and non-residential energy, which made up 31% of GHG emissions in 2017<sup>1</sup>. While these GHG emissions are from existing buildings, energy choices made by new development will have a significant impact on San José's ability to achieve its GHG emission reduction goals given the City's development forecast<sup>2</sup>.

In addition to reducing GHG emissions, the reach code and natural gas infrastructure prohibition ordinances are aligned with many of the key strategies under Climate Smart:

- 1.1 Transitioning to a renewable energy future
- 2.2 Making our homes energy efficient
- 3.1 Creating local jobs in our city to reduce Vehicle Miles Traveled
- 3.2 Improve our commercial building stock

---

<sup>1</sup> "Climate Smart San Jose: A People-Centered Plan for a Low Carbon City." City of San Jose, 2018.

<https://www.sanjoseca.gov/home/showdocument?id=32171>

<sup>2</sup> "Five-Year Economic Forecast and Revenue Projections, 2020-2024." City of San Jose Department of Planning, Building, and Code Enforcement, 2019. <https://www.sanjoseca.gov/home/showdocument?id=45694>

## Adopted Reach Code and Natural Gas Infrastructure Prohibition

On 09/17/19, City Council adopted the reach code ordinance, which applies to all new construction in San José. The reach code is an overlay of the 2019 California Building Code (also known as Title 24) and provides two different compliance pathways for all-electric versus mixed fuel new construction across all building occupancy types. All-electric buildings simply need to meet Title 24’s energy requirements while mixed fuel buildings are required to surpass Title 24’s energy efficiency requirements, and to be “electric-ready” in the future. In addition, the reach code also requires electric vehicle charging infrastructure (EVCI) and expands solar-readiness requirements in new construction.

Following the adoption of the reach code, on 10/29/19, Council adopted the natural gas infrastructure prohibition for new detached accessory dwelling units (ADU), single-family, and low-rise (three stories or fewer) multi-family buildings. Both ordinances went into effect on 01/01/20. In addition, at the time of adoption, City Council requested that staff return to Council with an analysis as to whether the City should require electrification for all wood-frame construction up to seven stories. The purpose of this report is to provide a technical analysis on the feasibility and recommended approaches to all-electric new construction for buildings over three stories.

The Planning, Building and Code Enforcement Department (PBCE) publishes a five-year development forecast annually detailing the projected new residential and non-residential construction for San José. The table below summarizes the projected number of units for single family (375) and multifamily (roughly 2,400) homes per year and the projected square footage for commercial (1.4 million) and industrial (1 million) square feet between 2020 and 2024. Unfortunately, the City’s development forecast does not distinguish between buildings based on height (i.e. number of stories), so identifying which buildings fall between 4-7 stories was not possible at the time of this report. Still, given the available forecasts, requiring all-electric new construction for buildings over three stories is expected to have a significant impact on the City’s GHG emissions and will help curb future emissions. This is due largely to the assumption that San José Clean Energy’s fuel mix will be 100% carbon-free by 2021; therefore, GHG emissions from all-electric buildings will be close to zero.

### Five-year development forecast (2021-2025)<sup>3</sup>

New Construction Building Type	19/20	20/21	21/22	22/23	23/24	24/25
Single family (# of units)	580	450	375	375	375	375
Multifamily (# of units)	2,400	2,375	2,375	2,375	2,375	2,375
Commercial (sq.ft., in thousands)	2,600	1,500	1,400	1,400	1,400	1,400
Industrial (sq.ft., in thousands)	1,000	1,000	1,000	1,000	1,000	1,000

<sup>3</sup> “Five-Year Economic Forecast and Revenue Projections, 2020-2024.” City of San Jose Department of Planning, Building, and Code Enforcement, 2019. <https://www.sanjoseca.gov/home/showdocument?id=54320>

## Scope of this Analysis

San José's natural gas infrastructure prohibition ordinance only applies to low-rise residential buildings, which includes single-family homes, low-rise multifamily buildings (up to 3 stories), and ADUs. This report assesses the technical, economic, and market-readiness feasibility of extending that prohibition to all buildings.

This report was originally intended to only cover the feasibility of the electrification of wood-framed buildings up to seven stories. However, during the Experts' Roundtable and follow-up conversations, there was a general consensus among participants that the issues for electrification are not substantially different for mid-rise and high-rise buildings, nor for wood-framed and other structural systems. The electric equipment and technologies that are used in high-rise buildings are also used in mid-rise buildings. The main difference is that mid-rise buildings can also sometimes utilize the technologies and strategies available for use in low-rise buildings.

Structure also does not have a significant impact on the feasibility of electrification. Wood, steel, and concrete structures are all capable of accommodating electric equipment. The superior strength of steel and concrete structures may provide added flexibility for all-electric designs since they can more easily support the weight of larger volumes of hot water storage utilized in central electric heat pump designs for multifamily buildings.

This report is divided into three sections: technical, economic and market feasibility. For the purposes of this report, feasibility is considered as a combination of the following factors:

### **Technical:**

- The feasibility of all-electric building technology and systems (e.g., HVAC, water heating), and
- The impact of all-electric building design on onsite electrical infrastructure like service sizes and onsite transformers.

### **Economic:**

- The cost effectiveness of all-electric new construction buildings (compared with mixed fuel)

### **Market:**

- The availability of electric equipment and technology that can be used in new construction as an alternative to gas equipment and appliances;
- The availability of the expertise to design and construct buildings that utilize that equipment and technology; and
- Market acceptance of electric alternatives to gas equipment.

Taking into account these considerations, different loads (i.e. energy demands) will pose greater and lesser degrees of difficulty to electrify in mid- and high-rise buildings. For example, the clear consensus among the stakeholders at the Experts' Roundtable (described below) was that the load that poses the greatest technical difficulty will be electrifying central water heating systems used in many multifamily and hotel buildings to serve domestic hot water load. Likewise, the clear consensus was that the load that poses the greatest market acceptance difficulty is the elimination of gas cooking. The barriers and

opportunities for electrifying these and other energy loads will be discussed in greater detail in the following sections.

## Sources

This report draws on several sources for this assessment including:

- **San José Building Electrification Experts' Roundtable:** In preparation for this report, San José held an Experts' Roundtable meeting in December 2019 (see Appendix A: Building Electrification Experts' Roundtable Participants) on the issues of electrifying mid- and high-rise buildings. This Roundtable brought together stakeholders and technical and market experts. Participants were led through a series of small group and large group discussions that explored the issues. The results of the Roundtable provide substantial insight for the City into the issues involved in building all-electric mid- and high-rise buildings.
- **Electrification Cost Effectiveness Reports:** The California Utilities Codes and Standards Program produced a series of cost effectiveness reports to support the adoption of electrification reach codes like San José's. It includes the costs and savings of all-electric designs for mid- and high-rise buildings. For the mid- and high-rise buildings studied, the reports found that all-electric buildings were less costly to construct than mixed-fuel buildings due to the considerable savings in gas infrastructure.<sup>4</sup>
- **Other Sources:** There are also other sources for information used in this report, including additional discussions with stakeholders, other reports and conference and webinar presentations, particularly presentations given by Ecotope, Inc., market research and interviews conducted by Building Electrification Initiative (BEI), and Steven Winter Associates, Inc. at the 2020 ASHRAE Winter Conference in Orlando, Florida.

## Feasibility & Approaches to All-Electric Buildings

This section assesses the feasibility of electrifying the various gas loads common in mid- and high-rise buildings.

### Technical Feasibility

The following sections of this report address the natural gas loads common in mid- and high-rise buildings individually, including water heating (both domestic and service), space conditioning, cooking (both residential and commercial), clothes drying, and additional miscellaneous loads.

#### Water Heating

It is important to note that electric water heating equipment includes both lower-efficiency electric resistance and higher-efficiency heat pump technology. The low efficiency of electric resistance equipment makes it very difficult for a building that includes electric resistance water heating to comply with Title 24. Therefore, this section focuses on the feasibility of heat pump-based systems and the technical issues of the way that they operate. While resistance-based equipment generates its own heat, heat pump-based systems actually move heat from the surrounding air or another source into the water. As they work by moving existing heat rather than generating it, heat pump water heaters are

---

<sup>4</sup> "2019 Nonresidential New Construction Reach Code Cost Effectiveness Study." Prepared by TRC Advanced Energy and EnergySoft for California Energy Codes and Standards Statewide Utility Program. Draft – 2019.

capable of achieving levels of efficiency 3-4 times their electric resistance counterparts and 4-5 times as efficient as their gas counterparts.

There are a handful of high-level technical considerations in the use of heat pump equipment for water heating:

- For a number of reasons<sup>5</sup>, heat pump water heating systems are most cost-effective when designed with large storage capacity and relatively slow recovery (lower heating capacity). For example, a load that could be served by a 40-gallon gas water heater would generally require a 50-gallon tank with a heat pump water heater. These larger storage volumes need to be incorporated into the building design.
- Most heat pump water heaters simply use ambient air as their heat source, so generally the source of heat is the air around the heat pump. The heat pump therefore needs access to a large enough volume of air to provide the heat to “pump” into the water. When heat pump water heaters are located indoors, this is an important consideration. If heat pumps are located in a traditional “boiler room”-sized or water-heater closet-sized space, they need a supply of ducted outside air to prevent over-chilling of the room, similar to how gas boilers require a large volume of combustion air and exhaust ductwork. Another option is to locate the heat pumps on the roof or in a below-ground garage where there is a sufficient air resource. Some heat pump water heaters utilize a ground source loop that pulls heat from underground, or from warm wastewater, and therefore do not need access to air.
- Since heat pump water heaters take heat from the surrounding air, they will cool and dehumidify the area where they are located. This can actually be advantageous in some circumstances.
- Heat pump water heaters generate noise with their compressor and fan, similar to air conditioners, chillers, air-handlers and other types of equipment. The level of noise varies considerably between products, and continues to drop from that of earlier generations of equipment. Additionally, water heaters are often located in locations where noise is not a significant issue. But noise can be an issue in some applications.
- Some heat pumps are far less efficient when reheating warm water compared to heating cold source water. This has an impact on the design and equipment selection in central water heating systems (discussed in greater detail below).

Hot water is delivered by two basic configurations of equipment: individual and central water heating systems. Hot water is sometimes categorized as domestic hot water and service hot water, but it is really these differences in the systems that create and deliver hot water that are important.

---

<sup>5</sup> These reasons for large storage and small heat pumps include: 1) Heat pumps use electricity, which is subject to demand (kW) charges, so smaller heat pump capacity will reduce demand charges; 2) smaller heat pump capacity will reduce wiring and electrical service requirements to the building, which reduce first cost; 3) time-of-use electricity pricing makes it beneficial to avoid using electricity during peak and partial-peak hours, and large storage capacity can potentially enable a HPWH system to ride through those periods without operating the heat pumps at all, then re-charge the tanks during off-peak hours when prices are low.



Figure 1: Central water heating with recirculation loop (left) versus individual water heaters (right) connected directly to the hot water points of use.

In individual water heating systems, the water heating equipment and the points of use for hot water are located close together and hot water flows directly from the equipment to the point of use. They cannot be located too far apart or else it will take too long to get hot water from the equipment to where it is needed. These systems are generally smaller (like the water heater in a single-family residence), but can be quite large in applications like restaurants or laundries.

In a central system, there is greater distance between the water heating equipment and the points of use and the points of use are not connected directly to the equipment. Instead, both the equipment and the points of use are connected to a recirculation loop that distributes hot water around the building. The recirculation loop ensures that there is always hot water near the points of use even though they may not be near the water heating equipment. The recirculation loop has to be kept hot when hot water draws are needed, which can be most of the day in buildings like apartments. The heat losses from a recirculation system can be substantial. Anecdotally, in systems with very efficient water heating equipment, heat losses from the distribution system can account for half of the total energy use of the entire water heating system.

The decision of whether to use an individual or central system is generally driven by the cost and/or value of square footage in the building. As buildings get taller, the higher value of space tends to incentivize the use of central systems with their lower total space requirements.

### Individual Systems

Individual systems are used in both residential and commercial occupancies in mid-rise and high-rise buildings. Individual systems are generally 50- to 120-gallon integrated heat pump water heaters, where the heat pump and the water storage tank are integrated in a single piece of equipment. Split-systems can also be used, and allow for larger storage tanks for larger loads.

In mid-rise buildings the 50- to 80-gallon tanks may be found in closets within the apartment, or in closets off the central hallway. Individual tanks vented to the interior of an apartment should be selected for their acoustic ratings—some brands have not invested in sound attenuation as much as others, and 49 decibels (e.g. Rheem brand) is experienced as half as loud as 55 decibels (AO Smith, Bradford White). Acoustic treatments can buffer the sound of louder products. When heat pump water heaters are located in a water heater closet, access to sufficient air is a significant issue. Louvred doors may not provide sufficient airflow into the closet, and ducting may be required. Venting water heater



closets to the hallway is an option to address concerns about noise, but could have an impact on the space conditioning of the hallway.

Individual systems are frequently used in commercial buildings for individual lavatories or kitchenettes. These are often smaller integrated units. Larger equipment is also used for commercial kitchens and laundries and are therefore more likely to be split-systems.

One kind of individual system resembles a central system. In a clustered system, a larger piece of equipment is used to serve multiple points of use, but without the use of a recirculation loop. Wait times for hot water are minimized through minimizing the volume of water between the water heating equipment and the furthest end use. This can be done through the use of a manifold connected to narrow pipe (such as 3/8") or a central supply line that has been reduced to the minimum size necessary. This is most frequently seen in multifamily buildings where the hot water points of uses in multiple units are clustered closely together.

### Central Systems

Central systems are also used in both residential and commercial occupancies in mid-rise and high-rise buildings. In central systems, the water heating equipment is located in a single central location or distributed central locations. In larger buildings, it can make sense to break the building into multiple water heating zones, but this is not unique to heat pump water heater systems.

Central systems are far more common than individual systems in buildings with larger, but distributed, water heating loads, especially mid- and high-rise multifamily buildings and hotels. If the loads are smaller and distributed – like bathrooms and kitchenettes in a large office building – multiple individual water heating systems are typically used. Central systems also will sometimes utilize multiple larger integrated heat pump water heaters ganged together, but this is less common than split systems in central systems.



Figure 2: Central gas water heating system (left) and central heat pump water heating system (right).

The defining feature of most central systems is the recirculation loop. Hot water is pumped through the recirculation loop to bring hot water closer to the points of use. The water in the recirculation loop needs to be kept hot when hot water draws are expected. In effect, there are two hot water loads: heating cold water for use in the building and maintaining the temperature in the recirculation loop. In a gas boiler system, these two loads are typically served simultaneously by the boiler with only minimal

storage. The warm return water from the recirculation loop is simply routed back through the boiler to be reheated.

However, the strategy of piping recirculation return back to the main hot water plant can create an issue for some heat pump water heaters, most notably those that use CO2 refrigerant. These heat pump water heaters are extremely efficient when heating water in a “single pass” from very cold to very hot, but are not as effective at reheating warm water. Therefore, if warm water is recirculated to a single-pass heat pump, the efficiency of the system can drop dramatically to near levels delivered by electric resistance equipment. The recommended approach for addressing this issue with single-pass heat pump water heaters is to separate the water heating and recirculation loop temperature maintenance loads and serve them with separate equipment. With this strategy, a heat pump water heater that is more effective at heating cold water can be selected to heat incoming cold water, while a heat pump water heater that is more effective at heating warm water can be used to keep the recirculation loop hot. Some practitioners have developed some highly effective and sophisticated strategies to maximize the efficiency of the single-pass approach with separate recirculation. These approaches are more complex, but maximizes efficiency.<sup>6</sup>

Some heat pump water heating equipment is more effective at re-heating warm water. These systems use what is known “multi-pass” operation, in which water from the tank is brought through the heat pump multiple times, each time adding 6-10 degrees of heat before being sent back to the storage tank. Multi-pass HPWH systems can be connected directly to the recirculation loop like a traditional gas boiler system, which simplifies design. This strategy can be used for many central heat pump water heating systems on the market that use traditional refrigerants like R134a, including products from AO Smith, Colmac, and Nyle, all of which can heat warm recirculation return water with less efficiency loss.

The large hot water storage tank used in central heat pump water heating systems can also pose a design challenge. Gas systems typically use large-capacity gas boilers with smaller tanks – with an overall smaller system footprint – to meet hot water demand. Designers will need to accommodate these larger tanks, which could contain thousands of gallons of water in some buildings, in their designs, ideally very early on. This will result in a change in the layout of the mechanical rooms in some buildings. However, there are numerous examples of this approach on mid-and high-rise housing in the San Francisco Bay Area. One potential source of additional space for these large HPWH storage tanks is the area vacated by deleting solar thermal (and the associated large storage tanks) in favor of additional solar PV (recommended for HPWH).

Access to air can also be an issue for large central systems. The heat pumps cannot be located in the same kind of small rooms typically used for boilers without ducting or dedicated ventilation. The ambient air in an enclosed room simply won't have sufficient heat for the larger water heating loads. Mechanical rooms can be vented to bring in outside air through louvers on the wall or an areaway to a basement. The heat pumps themselves can be vented to the outside, and most split system units are designed to accommodate this venting if needed. Heat pumps can even be ducted to the exhaust air of

---

<sup>6</sup> In fact, most of the more challenging technical issues in central water heating systems in taller buildings are not due to electric vs gas equipment at all, especially the issues with pressure that result from piping water vertically in a tall building.

the building and recover the waste heat and improve efficiency, or use the garage exhaust system as a source of outside air.

### **Modeling and Code Compliance**

Until recently there has been a modeling barrier in Title 24 for central heat pump water heating system in mid-rise and high-rise buildings. In February of 2020, this problem was resolved with the release of Title 24 functionality for high-rise central heat pump water heaters. The initial software functionality is for a single product that has been extensively installed and field tested in California since 2017, made by Sanden. For heat pump water heaters not yet field tested, the CEC has allowed central heat pump water heater systems comply with Title 24 Prescriptively, even when code compliance for the rest of the building is being demonstrated with the Performance path.<sup>7</sup> This makes it possible to demonstrate compliance with products by other manufacturers (e.g. Colmac, Nyle) without waiting for field testing, or seeking an extraordinary design approval which could add considerable time to the approval process.

### **Transforming the Market for Central Heat Pump Water Heating**

Based on our research and conversations with practitioners at the Expert’s Roundtable, the technology for individual water heaters is already widely available. Most of the barriers to the electrification of individual water heaters can be solved with thoughtful design. Water heaters need to be located so that they have access to sufficient heat for the load when they are located indoors. Where heat pumps are located indoors, the issue of noise will need to be addressed, but this can be addressed with careful selection of location. San José’s climate allows the heat pump to be located outside, which can solve both issues. Alternately, the issues of noise and access to heat can be addressed with vented heat pumps that allow heat pumps to be located in smaller and/or acoustically isolated spaces.

The biggest barrier to the electrification of central water heating systems in new construction is that the gas equipment cannot just be replaced with a heat pump water heater. A central heat pump water heater system has different design requirements that, while not especially complicated, are different from the standard designs for gas systems that have prevailed for years. According to interviews with some practitioners, the learning curve for central heat pump systems is much less than other high-performance systems like chilled beams and ground source heat pumps.

The consensus of the Roundtable participants was that the technology for these systems is widely available, even though finding it through distributors can occasionally be an issue. They identified the primary barrier as the need for more practitioners with experience and expertise with these systems. Right now, there are a small number of firms successfully designing these systems, so there is a need to transfer the knowledge and lessons learned by those pioneers to the broader market. The Roundtable participants suggested a handful of strategies that the City might employ to address this issue:

- **Design workshops:** The City could host professional development workshops where more experienced practitioners can train their peers how to effectively design central heat pump water heater systems. These workshops would preferably come with professional education credits since practitioners already have a need for continuing education. There is also a robust professional education infrastructure in the Bay Area to keep professionals informed of the

---

<sup>7</sup> “Executive Director Determination Pursuant to Section 1501(c)8C for Central Heat Pump Water Heating System.” [efiling.energy.ca.gov/GetDocument.aspx?tn=231318&DocumentContentId=63067](https://efiling.energy.ca.gov/GetDocument.aspx?tn=231318&DocumentContentId=63067).

regular code updates and the constantly changing market. The City could partner with other South Bay jurisdictions that have passed electric reach codes to host trainings.

- **Technical support from the City:** The City could contract some of the more experienced practitioners to assist and mentor project teams with less experience. In this way, the experience of the small number of experienced practitioners is spread out more broadly. Practitioners who are new to the design approaches would learn from more experienced practitioners and would have greater success in their early projects.
- **Guidance Documents:** A technical guide on how to design central heat pump water heating systems could be used by practitioners unfamiliar with the systems. There is a broader need for this kind of guidance, so San José may be able to partner with other organizations in its creation.
- **Equipment Manufacturers:** Many manufacturers of equipment hold regular education and training sessions at their distributors or in the offices of design engineers. Two such trainings have been held in the Bay Area in the past year. The City could host similar training sessions open to the profession.
- **Utility Continuing Education Programs:** PG&E also provides education and training series, as shown here: <https://pge.docebosaas.com/learn>.

## Space Heating

Air conditioning and ventilation are already almost universally provided by electric equipment for cooling, so the only real consideration for the electrification of HVAC loads is space heating. One fundamental consideration for the electrification of buildings is that electric heat does not necessarily mean electric resistance heat. Just as heat pump water heater can produce hot water far more efficiently than resistance water heaters, heat pump space conditioners can produce warm air far more efficiently than resistance heat systems. It can be difficult, if not impossible, to meet the energy requirements in Title 24 with electric resistance equipment unless they are serving small loads. There are some concerns about the performance of heat pumps in cold climates, but this is not a significant concern in San José's relatively mild climate.

The consensus of the Roundtable participants was that electric heating technologies mid- and high-rise buildings are already widely used and generally understood. Some mid-rise buildings can use the same technologies and equipment used in low-rise buildings. For example, some multifamily buildings use split-system heat pumps where each unit has its own outdoor heat pump located on the roof. Many buildings can also use Variable Refrigerant Flow (VRF) systems where multiple indoor units are connected to a single outdoor heat pump. There are limits on how long the refrigerant line that connects the indoor and outdoor units (these vary by equipment), so they are more common in mid-rise buildings (although they can be used in high-rises with careful design). The through-the-wall packaged heat pumps that are common in hotels can be used in taller buildings, and only become less common when buildings start to use curtain wall systems.

As buildings get taller, they have fewer system options in general, not just in all-electric buildings. Mixed-fuel high-rise buildings generally use a chiller and boiler to provide cooling and heating respectively to equipment inside the building. Heat pumps and "reverse chillers" can be used in place of boilers. It is important to note that as buildings get taller, they become more and more dominated by cooling loads and less by heating loads. This means that a tall building can be providing air conditioning to the spaces even during the winter when people's homes would be providing heat. As a result, as

buildings get taller, the cooling equipment becomes more dominant and the heating equipment becomes smaller. This makes it easier to electrify the heating equipment.

The equipment and expertise are already readily available to electrify HVAC equipment, so this does not present a significant barrier to all-electric mid- and high-rise buildings.

### Cooking

The issues for the electrification of cooking loads are very different for residential and commercial kitchens. While cooking ranges and cooktops are the primary issue for residential cooking, commercial kitchens have a much wider array of gas equipment that includes equipment like gas fryers. However, electric equipment already exists for both residential and commercial kitchens. Large portions of the U.S. do not use gas but rely primarily on electricity for their energy needs, yet they still cook food, so equipment is not the primary issue for electrifying cooking loads. In commercial kitchens, there are electric alternatives to all major appliances.

The technical feasibility issues for cooking have considerable overlap with market perception (discussed later in this report), but there is a genuine technical difference between cooking on gas ranges and traditional electric ranges. With gas ranges, the temperature can be changed more quickly and more minutely than traditional electric stoves. Electric resistance coil and ceramic cooktops tend to have a significant lag when changing temperatures and this has an impact on cooking. However, electric induction ranges offer a solution to this issue. These use an electromagnetic field to “induce” heat in ferrous cooking vessels like pots and pans. They allow the temperature to be changed as quickly and minutely as gas. Therefore, even for cooking ranges, adequate electric equipment alternatives exist.

### Clothes drying

Electric clothes dryers are widely available at the residential scale. Comments made at the Roundtable indicate that the market does not seem to have a preference for either gas or electric dryers. Larger “commercial” electric dryers are also widely available. However, as commercial dryers approach the very large sizes sometimes used in commercial laundries and hotels, electric models become less common. All-electric buildings with very large laundry loads, such as hotels, may need to alter their designs to accommodate different equipment layouts that utilize different dryer models. Heat pump dryers can also be an effective alternative to gas dryers.

### Other Gas Loads

Mid- and high-rise buildings can also have other, less common gas loads. These have their own considerations and are addressed briefly below:

**Gas Fireplaces:** There are electric alternatives to indoor gas fireplaces. One technology utilizes LED lighting to create a fairly convincing approximation of flames. It is worth noting that gas fireplaces were introduced as an alternative to wood fireplaces, and they too were only an approximation of the wood fires they replaced.

**Gas barbecues:** There are electric alternatives to free-standing gas barbecues. Additionally, while it is less than ideal considering San José’s Climate Smart goals, most free-standing barbecues are fueled by propane, which would not be impacted by a gas infrastructure prohibition.

**Swimming Pools:** Swimming pools often use gas boilers or water heaters to maintain pool temperature. Heat pump boilers are capable of filling this purpose. Additionally, many pools make use of solar thermal systems that use solar energy to heat water, so it is possible to eliminate this gas load without adding any electric load or equipment. The lower water temperatures needed for pools makes solar thermal heating particularly well-suited to pool water heating.

## Impact on Electrical Infrastructure

The increased electrical load that results from electrification can have an impact on the electrical infrastructure that serves all-electric buildings. These considerations include the impact on electrical service and transformer size and subsequently to the utility grid infrastructure and on back-up power requirements. Impacts to the utility grid infrastructure are outside of the scope of this analysis and should be evaluated by the utility or entity responsible for maintaining the grid infrastructure.

### Electrical Service and Transformer Capacity

Utilizing electric equipment instead of gas equipment does add electric load to those buildings. In mid- and high-rise buildings, this can have an impact on the electrical service size and/or the size of any onsite transformers that might be needed for the building. However, there are several important considerations that can mitigate the impact of electrification on the electrical capacity of the building:

- California's energy code is the most stringent state energy code in the U.S. California buildings are considerably more efficient than buildings in other jurisdictions and the impact of electrifying gas loads is therefore less than other jurisdictions with less efficient buildings.
- Mid- and high-rise buildings since taller buildings tend to be more dominated by cooling loads than low-rise buildings. Therefore, when heating can be provided by the same equipment that provides cooling, electrifying the heating load should not require any additional electrical capacity.
- The heating capacity (the size of the equipment) required for heat pump water heater systems is considerably less than their gas counterparts. According to stakeholders, the capacity of heat pump systems can be one quarter to one third the capacity required by gas water heating systems.
- Electrical service and transformer sizes are not very granular. There can be large steps between one transformer and the next size larger transformer and one electrical service size and the next size larger. As a result, some buildings have capacity to spare and some do not. According to participants at the Roundtable, it is very possible that some buildings will not need any additional capacity to accommodate the additional load, while others may trigger an increase in transformer service size. As a result, the impact of electrification on electrical service infrastructure costs are difficult to predict.
- Any costs that result from increases in electrical capacity would be mitigated by the savings from not installing gas infrastructure to the site. In all of the buildings analyzed by the 2019 Nonresidential New Construction Reach Code Cost Effectiveness Study, all-electric versions cost less to construct than their mixed-use counterparts.
- The biggest potential impact in the reach code on building electrical capacity is from the EVCI requirements. These will be the same regardless of whether the building is all-electric or mixed fuels.

- The electrical code allows the required capacity to be reduced when load management equipment is installed in the building. This equipment could be leveraged to reduce or avoid the need for increased electrical infrastructure in buildings due to the electrification of loads or addition of EVCI.

### Back-up Power Supply

Although some buildings include back-up power for all or most loads, in most buildings back-up power is only for emergencies and only serves essential systems. Few, if any, of the loads that would be electrified in an all-electric building would be necessary during an emergency. Space heating, water heating, cooking, and accessory loads like fireplaces and pools are generally not necessary in an emergency. Therefore, electrification is not likely to have any impact on emergency back-up systems. For buildings with full backup systems, electrification would increase the size of the system needed. However, this impact can be mitigated. One of the biggest loads, water heating in multifamily buildings and hotels, already essentially has an energy storage system built in. The larger storage tank required by heat pump water heaters means that they will have a larger store of hot water to serve the building in a power outage.

### Economic Feasibility

The California Energy Codes and Standards Statewide Utility program is currently working on cost effectiveness reports for the electrification of mid-rise and high-rise multifamily buildings. Both of these reports are still under development, but the mid-rise report is nearing completion and preliminary results are available. These preliminary findings show that all-electric mid-rise multifamily buildings can be less costly to construct than their mixed-fuel counterparts.

Figure 3 shows the construction cost difference between a central gas system and two different HPWH systems. The first system is a clustered HPWH system and the second is a central HPWH system with a recirculation loop. For San Jose's Climate Zone 4, the clustered system is less costly to construct than the central gas boiler, but the central system is more costly to construct than the central gas boiler. The market for central HPWH systems is still nascent, costs are expected come down as market adoption increases, manufacturers and installers achieve economies of scale, and innovation brings new technology to market. In the meantime, the clustered approach provides a cost-competitive pathway for electric water heating in mid-rise new construction.

Figure 4 shows the cost effectiveness of the clustered HPWH system. A benefit to cost ratio greater than one implies cost effectiveness is positive, a number less than one is not considered cost effective. In order to show cost differences for all-electric mid-rise buildings, two different benefit to cost ratios are used: time dependent valuation (TDV) and utility bill impacts (on-bill). The main difference between these two is that TDV considers the cost of electricity and natural gas during different times of the day and year whereas on-bill method applies IOU rates to estimated annual electricity and natural gas consumption. When considered on an on-bill basis, the clustered HPWH system has higher annual utility costs than the gas system. On a lifecycle basis, the increased annual utility costs outweigh the first cost savings. However, these projections do not take into account two key factors: 1) State incentives that are being developed under SB1477 and SGIP programs; 2) natural gas rates are expected to increase faster than electric rates as gas output declines due to several factors. These two factors would improve the cost effectiveness of central HPWH systems.

On a TDV (Time Dependent Valuation) basis, the clustered HPWH system has lower annual costs and lower lifecycle costs. TDV takes into account the long-term projected costs of providing power during peak periods, and therefore values savings during those peak periods more.

	Central Gas Boiler DHW	Clustered HPWH DHW	Central HPWH & PV
Total Cost Per HP or Boiler	\$106,105	\$3,962	\$14,224
Number of HPs / Boilers Reqd	1	32	15
Total Equipment Cost	\$106,105	\$126,778	\$213,364
Year of Replacement	15	15	15
Reduction in Cost	0%	15%	15%
Replacement Cost	\$68,105	\$69,168	\$116,408
20% Solar Thermal (npv)	\$73,735		
35% Solar Thermal (npv)	\$109,705		
PV Requirement (npv)			\$27,855
TOTAL - CZ1-9	\$247,944	\$195,946	\$357,627
TOTAL - CZ10-16	\$283,914	\$195,946	\$357,627
Inc Cost - CZ1-9		(\$51,998)	\$109,682
Inc Cost - CZ10-16		(\$87,968)	\$73,712

Figure 3: Costs for Gas versus Electric Water Heating Equipment

Climate Zone	Elec Utility	Gas Utility	Total Gas (therms)	Total Electric (kWh)	WITHOUT PV					WITH 1kW-DC PER APARTMENT			
					NPV Utility Cost Savings	NPV TDV Savings	Incremental Cost	TDV B/C Ratio	On-Bill B/C Ratio	Comp. Margin	NPV TDV Savings	Incremental Cost	TDV B/C Ratio
CZ01	PGE	PGE	97.6	649	-\$1,487	-\$291	-\$443	1.52	0.30	-7.2%	\$4,637	\$2,722	1.70
CZ02	PGE	PGE	97.9	-758	-\$838	\$266	-\$122	>1	0.15	0.1%	\$6,184	\$3,044	2.03
CZ03	PGE	PGE	94.3	-606	-\$940	\$35	-\$443	>1	0.47	-0.2%	\$5,894	\$2,722	2.17
CZ04	PGE	PGE	99.8	-686	-\$920	\$168	-\$122	>1	0.13	1.6%	\$6,323	\$3,044	2.08

Figure 4: Cost Effectiveness of mid-rise all-electric buildings

## Market Feasibility

The market for all-electric new construction in the Bay Area is still at an early stage, and while it is already at cost-parity or lower than mixed fuel construction in most cases, it is reasonable to expect that all-electric new construction has significant cost reduction potential as equipment becomes more common and the workforce more familiar and more competitive on all-electric new construction. Market acceptance is not a technical feasibility issue, but it is an important consideration. Consumer perception and preferences can create a non-technical barrier to electrification that the City can help to address. According to participants at the Roundtable, the market is generally open to electric equipment and the only major market preference that could pose a barrier is the elimination of natural gas cooking.



## Residential Cooking

In residential cooking, the primary barrier is a market preference for gas cooking by some consumers, and developer perception of market preferences. Gas cooking is seen as an amenity, and sometimes an essential amenity in higher-end projects. While using natural gas for cooking is more prevalent in the Northeast and West, electricity is still the most common fuel source for cooking in the U.S., particularly in the South. According to a survey conducted by the U.S. Energy Information Administration, 75% of households in the South reported having a cooking appliance that uses electricity<sup>8</sup>. Furthermore, there are recent studies indicating that customer perception may change with increased exposure to induction cooking. A recent customer research study conducted by the Sacramento Municipal Utility District (SMUD) found that 79% of customers had a negative impression of induction cooking prior to trying it, but a 91% positive impression afterwards. Additionally, many people believe that “gourmet” stoves are gas models, but Consumer Reports rate induction cooktops far ahead of gas in terms of performance.

### 2018 – 10 Top Rated Cooktops

Score	Cooktop
1. 100	Induction - Samsung \$2,000
2. 100	Induction - Dacor \$3,100
3. 99	Induction - GE \$1,800
4. 99	Induction - GE \$1,440
5. 99	Induction - GE \$2,600
6. 99	Induction - Kenmore \$1,600
7. 99	Induction - Bosch \$1,700
8. 97	Induction - Kenmore \$1,200
9. 97	Induction - Frigidaire \$700
10. 97	Induction - Frigidaire \$820
... 94	top rated Electric cooktop \$900
... 94	top rated Electric cooktop \$1,400
... 89	top rated Gas cooktop \$1,350



Residential gas cooking actually comes at a considerable cost in mid- and high-rise multifamily projects. The gas infrastructure required for gas cooking is substantial. Gas cooking also creates the need for more indoor ventilation, which increases the size and cost of the ventilation system. Because of these challenges, many mid- and high-rise residential projects already use electric cooking. Gas cooking is also very inefficient, with only about 30% of the energy consumed making it into the food, while electric cooking equipment can approach 90% efficiency.<sup>9</sup> Perhaps most significantly, gas cooking has a tremendous impact on indoor air quality. Gas cooking can release levels of pollutants that, if they were measured outside, would violate the Clean Air Act.<sup>10</sup> As a result, households with gas cooking have nearly three times that rate of treatment for asthma.<sup>11</sup>

<sup>8</sup> Woodward, M., & McNary, B. (2018, November 19). U.S. Energy Information Administration - EIA - Independent Statistics and Analysis. Retrieved from <https://www.eia.gov/todayinenergy/detail.php?id=37552>

<sup>9</sup> Frontier Energy. “Residential Cooktop Performance and Energy Comparison Study.” Prepared for Sacramento Municipal Utility District, July 2019.

<sup>10</sup> Gillis, J. and Nilles, B. (2019). “Your Gas Stove Is Bad for You and the Planet” The New York Times. [www.nytimes.com/2019/05/01/opinion/climate-change-gas-electricity.html](http://www.nytimes.com/2019/05/01/opinion/climate-change-gas-electricity.html)

<sup>11</sup> Jarvis et al. (1996) “Evaluation of asthma prescription measures and health system performance based on emergency department utilization.” <https://www.ncbi.nlm.nih.gov/pubmed/8618483>

Participants of the Roundtable suggested outreach programs to address these issues. San José already has an induction check-out program where residents can check out an induction countertop unit to give it a try and has hosted induction cooking workshops. The participants suggested going beyond that program with a public service style outreach program highlighting the indoor air quality issues of gas cooking in order to counteract any market preference for gas cooking.

### Commercial Cooking

Restaurants are a common occupancy on the ground floor of mid-rise and high-rise buildings and can be found in upper floors as well. Like residential cooking, the electric equipment for commercial kitchens is available. National food restaurants, for example, have both gas and electric options for their restaurants depending on what utilities are available. However, in many commercial kitchens, the use of gas is more than just a market preference. Commercial cooking is a production process and comprises part of the business model of restaurants. Professional chefs are often trained on gas equipment and the cooking processes in kitchens have often been built around the specifics of gas equipment. Therefore, electrification requires a change to production and business practices, not just market perception.

However, induction cooking is making inroads in commercial kitchens.<sup>12</sup> Since it only heats the pots and pans, induction cooking is safer than gas or electric resistance cooking. There is less chance of a fire, and less risk of burns from cooking staff. Induction ranges also put less heat into the kitchen, making them more comfortable and more likely to meet the new OSHA indoor occupational heat standards while also reducing cooling loads in kitchens. Many of the commercial kitchens in Silicon Valley tech office buildings are all-electric, and some global tech firms are now working to transition all of their kitchens from gas to electric.

### Market Feasibility Summary

All-electric equipment exists and is readily available for both residential and commercial kitchens, so there really is not a technical barrier. The main barrier is a market preference for gas cooking. A campaign based on the negative indoor air quality impact of gas cooking may be the best approach to address this barrier in the residential market. For commercial kitchens, Roundtable participants suggested high-profile all-electric kitchen pilots to help show professionals that induction cooking is not just a viable option to gas cooking but is preferable in many ways.

### Summary of Findings

All-electric mid-rise and high-rise buildings are possible in the San Jose market today. While there are obstacles to the universal adoption of all-electric buildings in San Jose, they are feasible:

- Electric equipment that can replace gas equipment is generally available. There may be some challenges with local distributors having ready access or stocking some electric equipment, but that will decrease as more and more all-electric buildings are built in San José.
- The load that poses the greatest difficulty for electrification is central water heating systems in multifamily buildings and hotels. The equipment is available, and the design approaches are

---

<sup>12</sup> Kostuch Media Ltd. (2017). Why Induction Cooking is the Hottest Trend to Hit Restaurant Kitchens. Food Service and Hospitality. [www.foodserviceandhospitality.com/why-induction-cooking-is-the-hottest-trend-to-hit-restaurant-kitchens/](http://www.foodserviceandhospitality.com/why-induction-cooking-is-the-hottest-trend-to-hit-restaurant-kitchens/)

well established. The issue with these systems that there is a need for more practitioners who have the experience and expertise to effectively design these systems. The Roundtable participants identified a handful of possible solutions to this issue including training workshops, technical resources, and technical assistance.

- The other load that presents barriers to electrification is cooking, especially in restaurant settings. For residential cooking, there is a perceived market preference for gas cooking. For commercial cooking, restaurant staff in California have frequently been trained on gas equipment and cooking processes have been developed around gas equipment. However, there are some restaurants in California already using all-electric kitchens. Addressing both of these issues may require public outreach and pilot programs that demonstrate the advantages of all-electric cooking over gas cooking and help overcome the business practice hurdle.
- There is the possibility that electrification of mid- and high-rise buildings could have an impact on the electrical infrastructure needed both on-site (service size and onsite transformers) and the grid. This impact can be unpredictable from building to building and can be mitigated through the use of load management equipment.
- A corollary benefit is the elimination of the gas service and the additional service request and time that several workshop participants mentioned a gas service often entails.

**Appendix A: Building Electrification Experts' Roundtable Participants**

<b>Participating Organization</b>	<b>Organization type</b>	<b># of attendees</b>
Alameda Municipal Power	Utility	1
Association for Energy Affordability	Engineering	1
Bayview Development Group	Real Estate Development and Investment Group	1
BCCI Construction	Developer/ Contractor	1
Charities Housing	Affordable Housing Development Nonprofit	1
City of San Jose	Municipality	12
Delivery Associates	Other	1
EDesignC Inc.	Engineering	1
EHDD	Architect	1
Fairfield Residential	Property Management Services	1
First Community Housing	Affordable Housing Development Nonprofit	1
Gensler	Architecture Firm	1
Guttman & Blavoet	Engineering	1
Hawley Peterson Snyder	Architecture Firm	1
HDS Construction Corp	Other	1
IBEW 332	Union	1
Integral Group	Electrical and Mechanical Engineering Firm	1
Joint Venture Silicon Valley	Environmental Non-Profit (General)	1
KTGY Architecture and Planning	Architecture Firm	1
Menlo Spark	Other	1
MidPen Housing	Affordable Housing Development Nonprofit	3
Natural Resources Defense Council	Environmental Non-Profit (General)	4
New Buildings Institute	Technical Expert	1
Norman S. Wright Mechanical	Manufacturer (HVAC)	2
NRG Engineering	Engineering	1

Panasonic	Manufacturer (heat pump AC units)	1
Santa Clara County Housing Authority	Other	1
Silicon Valley Clean Energy	Community Choice Energy	1
Smith Group	Design Firm	2
South Main Plaza LLC	Other	1
Stanford University	Educational Institution	1
SummerHill Apartment Communities	Other	1
Tommy Siu and Associates	Other	1
Urban Catalyst Fund	Other	1
Western Allied Mechanical Inc	Manufacturer	1
Total		53

**ATTACHMENT B: All-Electric Building Ordinances by Jurisdiction**

Jurisdiction	Systems		Building Types Covered							Life Sciences (Labs)	Municipal Property	Exemptions	Notes
	Whole Building	Water and Space Heating Only	Low Rise Residential	High Rise Residential	Hotel	Retail	Office	Restaurant					
Alameda	X									X		Gas ban	
Berkeley	X		X	X	X	X	X	X	X	X		Gas ban	
Brisbane	X		X	X	X	X	X	X		X	Low-rise residential cooktops and fireplaces; for-profit cooking appliances (e.g. restaurants, commercial kitchens, etc.)		
Cupertino	X		X	X	X	X	X	X		X	ADUs, nonresidential kitchens, factories, hospitals/ emergency centers, other research/development, and essential facilities	All exempted uses, except hospitals/ emergency centers, must provide electric-readiness	
Hayward	X		X							X	ADUs up to 400 sqft	Gas ban	
Healdsburg	X		X		X	X	X	X	X	X	Essential services (includes hospitals/ emergency center), technical processes, residential and nonresidential cooktops, fireplaces and pools/spas	All exempted uses, except hospitals/ emergency centers, must provide electric-readiness	
Los Gatos	X		X										
Menlo Park	X	X	X	X	X	X	X	X	X	X	Hospitals/ emergency centers, residential appliances other than water heating, space conditioning, and clothes drying systems (e.g. pool, stoves and fireplaces), lab space heating, and nonresidential cooking appliances	All exempted uses, except hospitals/ emergency centers, must provide electric-readiness	
Morgan Hill	X		X	X	X	X	X	X	X	X		Gas ban	
Mountain View	X		X	X	X	X	X	X		X	Hospitals/ emergency centers and for-profit cooking appliances		
Palo Alto	X		X							X			
Richmond	X	X	X	X	X	X	X	X		X	Hospital/ emergency centers, residential stoves, and fireplaces, and for-profit cooking appliances	All exempted uses, except hospitals/ emergency centers, must provide electric-readiness	
San Francisco	X									X		Gas ban	
San José	X		X							X		Gas ban	
San Mateo County	X		X	X	X	X	X	X	X	X	Hospitals/ emergency centers, lab space heating, for-profit cooking appliances may apply	All exempted uses, except hospitals/ emergency centers, must provide electric-readiness	
Santa Rosa	X		X										
Windsor	X		X										
Carlsbad		X	X								Space heating	Gas ban for water heating only	
Campbell		X	X										
Los Altos Hills		X	X							X			
Pacifica		X	X		X	X	X	X		X	Hospitals/ emergency centers, residential stoves and fireplaces, ADUs, and for-profit cooking appliances	All exempted uses, except hospitals/ emergency centers, must provide electric-readiness	
Saratoga		X	X							X	Residential cooktops, fireplaces, and clothes dryers	All exempted uses must provide electric-readiness	

## Attachment C: Summary of Building Electrification Experts' Roundtable Discussion

### Software Modeling for HPHW and Others

Problem/Challenges
<p><b>CHALLENGE 1: Prescriptive option (no credit but no penalty)</b> <b>CHALLENGE 2: Exceptional modeling process for the City→ CEC takes too long (6-12 months)</b></p> <ul style="list-style-type: none"><li>○ Limited controls input (commercial side)</li><li>○ High rise: 15% penalty</li><li>○ Systems not credited for full performance (i.e. variable capacity heat pumps)</li><li>○ Central plants issue: recirculating control modeling</li><li>○ Thermal storage hot water: not able to model yet</li><li>○ There is a lag; modeling still assumes gas is required. Certain types of systems not supported in modeling</li><li>○ Energy Plus + Seeback cannot run the modeling now for large scale heat pumps</li><li>○ Stop gap solutions in the near time, more long-term solutions in 3-9 months</li><li>○ Issues between using design tool to “pass” versus designing to save energy</li><li>○ Credit for load management (not offered/available)</li><li>○ Little credits for new technology; slow adoption of new technologies</li><li>○ Existing software developers may not have the needed resources for modeling, need more bandwidth</li><li>○ VRF needs interim solution for modeling</li><li>○ Generally, more opensource working on software solutions</li></ul>
Solutions
<p><b>SOLUTION 1: Funding for calculations tools (C1)</b> <b>SOLUTION 2: System that supports innovation AND more quickly (C2)</b></p> <ul style="list-style-type: none"><li>○ IOU or other staff assist with review; other projects use previously submitted calculations; calculator/spreadsheet for projects to use; city advocates push for change; increased flexibility with credits</li><li>○ Compliance credit for HPWH w/controls for time of use</li><li>○ CEC addressing mid-rise baseline modeling (address TDV penalty); February 2020</li></ul>

**Market Readiness: What is needed to transition to the market (workforce, demand, product)**

Problem/Challenges
<p><b>CHALLENGE: 1) Lack of awareness or misconception of electric appliances (C1)</b></p> <p><b>Cooking:</b></p> <ul style="list-style-type: none"><li>○ Misconception: people w/health challenges, elderly will be worse off, won't have heat</li><li>○ Need for fireplace, BBQ</li><li>○ Not understanding cost differences between e.g., electrical &amp; propane BBQ</li><li>○ Cultural - I need to cook on gas; Limitations - I can't cook w/ a wok on electric coils</li><li>○ Induction is more expensive</li><li>○ Perception - gas is seen as a premium that rental owners can charge more for</li><li>○ Adoption has been easier in affordable housing developments for that reason (even though it's way cheaper to not build the whole trench / gas infrastructure)</li><li>○ Are amenities listed by what's most appealing, e.g., EV charging, gas/induction stove</li></ul> <p><b>CHALLENGE: 2) Limited # of designers/professionals for central HPWH (C2)</b></p> <p><b>Capacity / workforce:</b></p> <ul style="list-style-type: none"><li>○ Workforce, trades<ul style="list-style-type: none"><li>○ Everyone is maxed out on work right now – market is hot, may be hard to find people to do this work</li><li>○ Getting rid of gas piping, gets rid of industry, whole job – but usually it's plumbers (so not exactly whole industry)</li></ul></li><li>○ Plumbers could install electrical water heaters but when something goes wrong, it's electricians who need to fix it</li></ul>
Solutions
<p><b>SOLUTION 1) Increase and improve public perception of electric appliances (C1)</b></p> <ul style="list-style-type: none"><li>○ Demonstration house w/electric appliances<ul style="list-style-type: none"><li>○ Chef tour w/induction stoves &amp; cooking, famous chef (e.g., Thomas Keller, French Laundry) open a restaurant in San José</li><li>○ Campaign on (public) health &amp; safety</li><li>○ Fire dept, insurers – reduce costs, requirements</li></ul></li><li>○ Promote induction –<ul style="list-style-type: none"><li>○ Example - CFLs were expensive at first... now LEDs etc. are cheap</li><li>○ Consumer Reports - top 10 burners are all induction</li><li>○ Best gas more expensive than those top 10 – starting to get cost-competitive</li></ul></li><li>○ Cooking experience largely the same<ul style="list-style-type: none"><li>○ New study: induction much more efficient than gas, not more efficient than other electric stoves</li><li>○ Induction speed comparable to or faster than gas</li></ul></li><li>○ Provide incentives to purchase induction stoves (like EVs)</li><li>○ Buy in bulk, e.g., for whole building, or even across buildings</li><li>○ Targeted incentives for fuel switching, help people transition off, cut the line</li></ul>



- First stop building new gas
- Then map out where you can pull the gas in from, geographically
- Overlay that with income, so low-income folks are helped first, not stranded
- Marketing electrified buildings generally - Health: gas
  - Air quality – kids, women (study recently) – asthma, etc., impacts

**SOLUTION 2) Knowledge sharing and streamlining needed, e.g., design guide for heat pump water heater (C2)**

## Electrical Capacity: Transformer Upgrades & Sizing for EVCI Requirements

### Problem/Challenges

#### **CHALLENGE 1) Load Management (C1)**

- There are big load spikes in the evening when everyone gets home - increases needed capacity (especially in residential areas)
  - Load controllers right now are all local, not networked - doesn't prevent spikes at a district level. Some let load go up to the max service rating
  - Lack of demand response
  - Demand response tech is not being utilized by utilities, even though energy code requires it to be put in
  - People don't always use available load management tools - new cars come with charging timers, but a Peninsula Clean Energy study showed that only half of the people use them
  - People may not want demand response controlled by utilities
- EV charging increases needed capacity
  - Adding only 8-9 EV spaces to a project leads to electrical engineers saying that an additional transformer is needed
  - An EV charger doubles the load of a single-family home (Title 24 2019 already requires EV Ready for single family homes)
  - Project may require increased transformer size
  - Load management issues will become greater as EV charging loads increase

#### **CHALLENGE 2) No consensus on the basics (i.e. how do loads increase? how much capacity is needed? what do you need to design to?) (C2)**

- Electrical engineers only suggest increasing transformer number/size - don't consider load-management tech as an alternative solution
- PG&E installation lead time - backlog of requests for installing electrical infrastructure
- Capacity - more people are needed at all levels (design, engineers, building, installers, inspectors ...) - this is particularly a challenge because of low, local unemployment
- Site constraints & age of existing infrastructure can be limiting
- Induction cooktops increase needed capacity, because they have a higher maximum load than electrical resistance cooktops (only marginally higher, and load is for shorter duration, but still affects calculations)
- Transformers require deposits - if transformers are not used up to 50-75% of their capacity, the deposit may be wasted
- Standard software won't model all-electric high-rises unless you go prescriptive

### Solutions (Electrical Capacity)

#### **Solution 1) New technology could reduce peak loads (C1)**

- Battery storage (plus solar?) - expensive though - and solar may offset EV loads in single family homes, but likely not in multifamily

- EVs as batteries - may be only feasible for emergencies? More complex in multifamily housing
- Software controllers that would space out when cars start charging, or reduce charge speeds if loads are high
- Peninsula Clean Energy is piloting tech for homes which allows customers to control charging from home
- Community Energy Utilities may be able to take the lead on using demand response tech
- Time of use management/smart homes - could categorize different uses into “buckets” depending on whether they can be interrupted/shifted around in order to automate load management
- New pricing structures that encourage people to use electricity at non-peak times
  - Alameda Muni Power piloting peak rates for EV charging
  - Dynamic pricing

**Solution: 2) Education for electrical engineers and other stakeholders (C2)**

- Technical roundtables, for example

**Other Solutions**

- Cost sharing/incentives to have CCAs or cities help cover the costs of electrical infrastructure needed in new developments
- More public power/CCA control
- Carbon tax could help fund EV infrastructure
- Increased energy efficiency can partly offset increased load from EVs
  - E.g., passive houses/houses with a tight envelope - but they’re expensive, and continuous insulation systems for exteriors (without thermal breaks) aren’t yet sufficiently developed

## Heat Pump Water Heaters & Multi-family Buildings or Mixed-Use Buildings

### Problem/Challenges

#### **CHALLENGE: 1) Lack of familiarity/market awareness with electric HPWH**

- Sizing is a concern
  - No set guidelines for sizing to meet electrical requirements and demand
  - Multi-family buildings have 24-hour demand; one heat pump can't maintain load, needs more space in high-rise
- Combining trades of plumbing v/s HVAC
  - Uncertainty with what kind of training/licensing is required (i.e. Do plumbers need to get a HVAC contractor license or additional training? License to handle refrigerants such as freon? Which trade is responsible for maintenance of electric appliances?)
  - In affordable housing, most maintenance doesn't get done; can worsen issue
- Standard HPWH not as efficient as mini-split
- Electrical room requirements and sizing
  - Space constraints with larger loads; clash between EV and HPWH loads; developers complain about compressors failing
- Cost of equipment and infrastructure can be an issue

### Solutions

#### **Solution: 1) Increase market familiarity with HPWH (C1)**

- PG&E offers monthly training opportunities for trades, need better advertising
- Demand for training will increase as they appear in bid documents

#### **Solution: 2) Design guidance and sizing resources (C1)**

- Ecotope is a leader in sizing and has resources available
- Sizing and technology best practices:
  - Size storage to meet peak demand; size heat pump to recharge storage for load shifting
  - Multi-pass technology is preferred (even though slightly less efficient than single-pass). Single pass is complicated; doesn't have recirculation and needs more equipment for separate recirculation
  - Design for all-electric from the beginning; design for air supply (which can add significant loads), don't put HPWH in mission-critical room
  - Load increase made shift to next load in transformer
- Decentralized approach - Each apartment can have their own HPWH
  - No need for recirculation; savings from no central hot water distribution; no sub-meter needed for hot water, cold water is sufficient; footprint of HPWH per apartment or family unit makes sense (not necessarily for studio); heat from fridge balances cool from HPWH; not loud
  - Mini-split preferred in wooden structures but not in concrete parking

## Affordable Housing and Electrification

### Problems/Challenges

#### **Challenge: 1) Funding requirements and hurdles**

- Bay Area - there are funding challenges b/c tax credit funding caps are based on general CA construction costs and Bay Area costs are a lot higher. Also, lag time /w updating tax credit cost and rapidly increasing construction costs.
- Tax Credit Allocation Committee - no points for electrification
- Affordable housing funding has many requirements
- Short design timeframe required; makes going all electric very difficult as contractors & designers need more time to design all electric (learning curve)
- Hard to utilize grant money w/ tax credit program b/c it can count as income

#### **Challenge: 2) Cost/Ease of maintenance and Commissioning**

- High turnover rates in maintenance staff on site. Lack of knowledge about new equipment. Do not want to rely on service contractor; need on-site maintenance staff

#### **Other Challenges**

- Subject to prevailing wages
  - Few subcontractors are available because of 6-month period to build
- PSPS shutoff- there is skepticism around all-electric
- Added load from EV requirements during peak use (i.e. Will there be winter shut offs due to overload? Happens in Europe regularly)
- Limited subcontractors who can work on affordable housing projects
- Added space from heat pump water heaters increases cost

### Solutions

#### **Solution: 1) Public policy changes (C1)**

- TCAC funding requirements and structure need to change to suit process of affordable housing creation.

#### **Solution 2: Technical Assistance (C1)**

- Assistance from the City of San José. Can help speed up design timeframe if designers and contractors have more training and assistance

#### **Other Solutions**

- Put one heat pump water heater on each floor, or centralized unit in parking structure area to avoid challenges with limited space and size of the heaters.
- Go all electric from the start! Lowers cost overall (ex: 5 big UC buildings are all electric, and were successful because of the foresight)
- Make all-electric is the new normal. Frame all-electric projects as a good opportunity for contractors and designers to learn new skills for rapidly changing market.
- Examine bids holistically. All-electric should not be more expensive. Better bid process means more feasible projects.

ATTACHMENT D

ORDINANCE NO.

**AN ORDINANCE OF THE CITY OF SAN JOSE  
AMENDING SECTION 24.12.300 OF CHAPTER 24.12 OF  
TITLE 24 (TECHNICAL CODES) OF THE SAN JOSE  
MUNICIPAL CODE RELATED TO THE REACH CODE  
REQUIREMENTS FOR MIXED FUEL BUILDINGS TO  
MAKE CLERICAL EDITS**

**WHEREAS**, pursuant to Sections 17922, 17958, 17958.5 and 17958.7 of the California Health and Safety Code, the City may adopt the provisions of the Green Building Standards Code and Building Efficiency Energy Standards with certain amendments to those provisions which are reasonably necessary to protect the health, welfare and safety of the citizens of San José because of local climatic, geological and topographical conditions; and

**WHEREAS**, on October 1, 2020, the City Council made specific findings related to the local geological, topographical and climatic conditions relating to the amendments to the California Codes for which such findings are required;

**WHEREAS**, the City Council hereby determines that the findings remain accurate and hereby adopts, affirms, and incorporates them by reference as if set forth in full;

**WHEREAS**, on October 1, 2020, the City Council made the additional findings with respect to cost effectiveness of any amendments to the California Codes for which such findings are required;

**WHEREAS**, the City Council hereby determines that the findings remain accurate and hereby adopts, affirms, and incorporates them by reference as if set forth in full;

**WHEREAS**, this Ordinance was found to be categorically exempt from environmental review, per the provisions of the California Environmental Quality Act (CEQA) of 1970, as amended, 14 California Code of Regulations Section 15308, and Title 21 of the San José Municipal Code, under File Number PP19-067; and

**WHEREAS**, the City Council of the City of San José is the decision-making body for this Ordinance; and

**WHEREAS**, this Council has reviewed, considered, and approves the Statement of Exemption determination under CEQA prior to taking any approval actions on this Ordinance;

**NOW THEREFORE, BE IT ORDAINED BY THE COUNCIL OF THE CITY OF SAN JOSE:**

Section 24.12.300 of Chapter 24.12 of Title 24 of the San José Municipal Code is hereby amended to read as follows:

**24.12.300 Additional Requirements for Mixed—Fuel Buildings (Amending Energy Standards, Subch. 4, to add §130.6)**

Energy Standards, Subchapter 4 is amended to add Section 130.6 to be numbered, entitled, and to read as follows:

**130.6 Additional Requirements for Mixed Fuel Buildings:** Mixed Fuel Buildings shall also include the following additional components:

**A. Water Heaters**

- i. A dedicated 240-volt electrical receptacle with a minimum capacity of 30 amps that is connected to the electrical panel with conductors of adequate capacity, within 3 feet from the water heater and accessible to the water heater with no obstructions.
- ii. Both ends of the unused conductor shall be labeled with the words “For Future Heat Pump Water Heater” and be electrically isolated.
- iii. A condensate drain that is no more than 2 inches higher than the base of the installed water heater and allows natural draining without pump assistance.
- iv. Located in an area with a minimum of 700 cubic feet of volume, or a ducting plan for eight-inch supply and exhaust ducts to the exterior or a space with 700 cubic feet of volume.

Exception: The space and ventilation requirements may be reduced to conform with the manufacturer’s recommendations for a specific heat pump hot water heater that meets the requirements of Sections 110.0, 110.1 and 110.3.

**B. Clothes Drying**

- i. A dedicated 240-volt electrical receptacle with a minimum capacity of 30 amps that is connected to the electrical panel with conductors of adequate capacity, within 3 feet of the appliance and accessible with no obstructions.
- ii. Both ends of the unused conductor shall be labeled with the words “For Future Electric Clothes Drying” and be electrically isolated.

- C. Cooktop or Range A dedicated 240-volt electrical receptacle with a minimum capacity of 50 amps that is connected to the electrical panel with conductors of adequate capacity, within 3 feet of the appliance and accessible with no obstructions.
- i. Both ends of the unused conductor shall be labeled with the words "For Future Electric Range" and be electrically isolated.

EXCEPTION to A, B, and C: If gas or propane plumbing is not installed for the specified end uses.

D. Other Gas Equipment.

- i. For equipment that is specified or connected to natural gas or propane plumbing, the building shall include designated raceways and reserved capacity on the main electrical panel and subpanels, if applicable, sufficient to power electric equipment that provides the equivalent function as the intended function of the gas equipment; or,
- ii. If gas plumbing exists but no gas equipment is specified or connected, the building shall include designated raceways and reserved capacity on the main electrical panel and subpanels, if applicable, sufficient to provide equivalent power at a maximum gas flow rate under normal gas service pressure. Plans shall include calculations for delivered gas power and equivalent electrical power, conductors, raceway sizes and panel capacities.

Exception to D. If the applicant demonstrates that there is no viable electrical equipment that can perform the intended function of the gas equipment.

- E. All newly installed raceways between the main electrical panel and any subpanels, and the point at which the conductors serving the building connect to the common conductors of the utility distribution system shall be sized for conductors adequate to serve all of the building's electrical requirements, including PV as specified Section 140.0(b)1 and future electric loads as specified in Section 140.0(b)2.

- F. If the building includes an electrical transformer(s) feeding the main panel or any subpanels, the transformer(s) shall be located in a space large enough to accommodate a transformer(s) with a rated capacity sufficient to serve all of the building's electrical requirements, including PV as specified in Section 140.0(b)1 and future electric loads as specified in Section 140.0(b)2.

**SECTION 15.** Chapter 24.12 of Title 24 of the San José Municipal Code is hereby amended by adding a Part to be numbered, entitled, and to read as follows:



**Part 4**  
**Nonresidential, High-Rise Residential, and Hotel/Motel Occupancies –  
Performance and Prescriptive Compliance Approaches for Achieving Energy  
Efficiency (Energy Standards, Subch. 5)**

**24.12.400 Performance and Prescriptive Compliance Approaches (Energy  
Standards, Subch. 5, §140.0)**

Energy Standards, Subchapter 5, Section 140.0 is amended to read as follows:

- (a) The requirements of Sections 100.0 through 110.12 applicable to the building project (mandatory measures for all buildings).
- (b) The requirements of Sections 120.0 through 130.6 (mandatory measures for nonresidential and high-rise residential and hotel/motel buildings).
- (c) Either the performance compliance approach (energy budgets) specified in Section 140.1 or the prescriptive compliance approach specified in Section 140.2 for the Climate Zone in which the building will be located. Climate zones are shown in FIGURE 100.1-A.

NOTE to Section 140.0(c): The Commission periodically updates, publishes and makes available to interested persons and local enforcement agencies precise descriptions of the Climate Zones, which is available by zip code boundaries depicted in the Reference Joint Appendices along with a list of the communities in each zone.

NOTE to Section 140.0: The requirements of Sections 140.1 through 140.9 apply to newly constructed buildings. Section 141.0 specifies which requirements of Section 140.1 through 140.9 also apply to additions or alterations to existing buildings.

**24.12.410 Performance Approach: Energy Budgets (Energy Standards, Subch. 5  
§140.1)**

Energy Standards, Subchapter 5, Section 140.1 is amended to read as follows:

A newly constructed All-Electric Building complies with the performance approach if the energy budget calculated for the Proposed Design Building under Subsection (b) is no greater than the energy budget calculated for the Standard Design Building under Subsection (a).

A newly constructed Mixed-Fuel Building complies with the performance approach if the compliance margin exceeds the value in Table 140.1-A below. The compliance margin shall be calculated by subtracting the energy budget calculated for the Proposed Design Building under Subsection (b) from the energy budget calculated for the Standard Design Building under Subsection (a) and dividing the result by the energy budget calculated for the Standard Design Building under Subsection (a).

Table 140.1-A Mixed Fuel Building Compliance Margins

Occupancy Type	Compliance Margins
Office Building	14%
Retail Store	14%
Hotel/motel and High-rise residential	6%
Industrial/Manufacturing	0%
All other Nonresidential occupancies	6%

- (a) Energy Budget for the Standard Design Building. The energy budget for the Standard Design Building is determined by applying the mandatory and prescriptive requirements to the Proposed Design Building. The energy budget is the sum of the TDV energy for space-conditioning, indoor lighting, mechanical ventilation, service water heating, and covered process loads.
- (b) Energy Budget for the Proposed Design Building. The energy budget for a Proposed Design Building is determined by calculating the TDV energy for the Proposed Design Building. The energy budget is the sum of the TDV energy for space-conditioning, indoor lighting, mechanical ventilation and service water heating and covered process loads.
- (c) Calculation of Energy Budget. The TDV energy for both the Standard Design Building and the Proposed Design Building shall be computed by Compliance Software certified for this use by the Commission. The processes for Compliance Software approval by the Commission are documented in the ACM Approval Manual.

EXCEPTION 1 to Section 140.1. For newly constructed buildings, if the Certificate of Compliance is prepared and signed by a Certified Energy Analyst and the energy budget for the Proposed Design is no greater than the Standard Design Building, the required compliance margin is reduced by 1%.

**24.12.420 Prescriptive Approach (Energy Standards, Subch. 5, §140.2)**

Energy Standards, Subchapter 5, Section 140.2 is amended to read as follows:

To comply using the prescriptive approach, a building shall be designed with and shall have constructed and installed systems and components meeting the applicable requirements of Sections 140.3 through 140.9 and the following requirements as applicable:

- (a) Hotels and Motels
  - 1. Install fenestration with a solar heat gain coefficient no greater than 0.22.

2. Design Variable Air Volume (VAV) box minimum airflows to be equal to the zone ventilation minimums.
3. Include economizers and staged fan control in air handlers with a mechanical cooling capacity  $\geq 33,000$  Btu/h.
4. Reduce the lighting power density (Watts/ft<sup>2</sup>) by ten percent (10%) from that required from Table 140.6-C.
5. In common areas, improve lighting without claiming any Power Adjustment Factor credits:
  - A. Control to daylight dimming plus off per Section 140.6(a)2H, and
  - B. Perform Institutional Tuning per Section 140.6(a)2J
6. Install one drain water heat recovery device per every three guest rooms that is field verified as specified in the Reference Appendix RA3.6.9.

(b) High-rise Residential and All Other Nonresidential Buildings

1. Install fenestration with a solar heat gain coefficient no greater than 0.22.
2. Limit the fenestration area on east-facing and west-facing walls to one-half of the average amount of north-facing and south-facing fenestration.
3. Design Variable Air Volume (VAV) box minimum airflows to be equal to the zone ventilation minimums where VAV systems are installed.
4. Include economizers and staged fan control in air handlers with a mechanical cooling capacity  $\geq 33,000$  Btu/h.
5. Reduce the lighting power density (Watts/ft<sup>2</sup>) by ten percent (10%) from that required from Table 140.6-C.
6. Improve lighting without claiming any Power Adjustment Factor credits:
  - A. Perform Institutional Tuning per Section 140.6(a)2J, and
  - B. In office spaces, control to daylight dimming plus off per Section 140.6(a)2H, and
  - C. Install Occupant Sensing Controls in Large Open Plan Offices per Section 140.6(a)2I.

SECTION 16. Chapter 24.12 of Title 24 of the San José Municipal Code is hereby amended by adding a Part to be numbered, entitled, and to read as follows:

**Part 5**  
**Low Rise Residential Buildings – Mandatory Features and Devices (Energy Standards, Subch. 7)**

**24.12.500 Mandatory Features and Devices for Low-Rise Residential Buildings (Energy Standards, Subch. 7 §150.0)**

Energy Standards, Subchapter 7, Section 150.0 is amended as follows:

Low-rise residential buildings shall comply with the applicable requirements of Sections 150(a) through 150(s).

NOTE: The requirements of Sections 150.0 (a) through (s) apply to newly constructed buildings. Sections 150.2(a) and 150.2(b) specify which requirements of Sections 150.0(a) through 150.0(r) also apply to additions or alterations. The amendments to sections 150.0 (h), 150.0 (n), 150.0 (s) do not apply to additions or alterations .

(a) – (g): Subsections 150.0(a) – (g) are adopted without modification.

(h) **Space-Conditioning Equipment** is amended to add a sub-subsection 150.0(h)(5) to read as follows:

5. Systems using gas or propane space heating equipment shall include the following components:
  - A. A designated exterior location for a future heat pump compressor unit with either a drain or natural drainage for condensate from possible future operation as cooling equipment.
  - B. A dedicated 240-volt, 30-amp electrical circuit that is connected to the electrical panel with conductors of adequate capacity, terminating within 3 feet from the designated future location of the compressor unit with no obstructions. In addition, all of the following:
    - i. Both ends of the unused conductor shall be labeled with the word “For Future Heat Pump Space Heater” and be electrically isolated; and
    - ii. A double pole circuit breaker in the electrical panel labeled with the words “For Future Heat Pump Space Heater”.

EXCEPTION to Section 150.0(h)5.B. If a 240-volt electrical circuit with a minimum capacity of 30 amps exists for space cooling equipment.

(i) - (m): Subsections 150.0(i) – (m) are adopted without modification.

(n) **Water Heating System** is amended read as follows:

1. Systems using gas or propane water heaters to serve individual dwelling units shall include the following components:
  - A. A dedicated 240 volt, 30-amp electrical receptacle that is connected to the electrical panel with conductors of adequate capacity, within 3 feet from the water heater and accessible to the water heater with no obstructions. In addition, all of the following:
    - i. Both ends of the unused conductor shall be labeled with the words, "For Future Heat Pump Water Heater" "" and be electrically isolated; and
    - ii. A double pole circuit breaker in the electrical panel labeled with the words "For Future Heat Pump Water Heater".
  - B. A Category III or IV vent, or a Type B vent with straight pipe between the outside termination and the space where the water heater is installed; and
  - C. A condensate drain that is no more than 2 inches higher than the base of the installed water heater, and allows natural draining without pump assistance, and
  - D. A gas supply line with a capacity of at least 200,000 Btu/hr. Located in an area that is both:
    - i. At least 3 feet by 3 feet by 7 feet high; and
    - ii. Has a minimum volume of 760 cubic feet or a ventilation plan that includes the equivalent of one 16 inch by 24 inch grill for warm supply air and one 8 inch duct of no more than 10 feet in length for cool exhaust air.

EXCEPTION to 150.0(n)1.D. The space and ventilation requirements may be reduced to conform with the manufacturer's recommendations for a specific heat pump hot water heater that meets the requirements of Sections 110.0, 110.1 and 110.3.
2. Water heating recirculation loops serving multiple dwelling units shall meet the requirements of Section 110.3(c)4.
3. Solar water-heating systems and collectors shall be certified and rated by the Solar Rating and Certification Corporation (SRCC), the International Association of Plumbing and Mechanical Officials, Research and Testing (IAPMO R&T), or by a listing agency that is approved by the Executive Director.

4. Instantaneous water heaters with an input rating greater than 6.8 kBTU/hr (2kW) shall meet the requirements of Section 110.3(c)7.
5. Systems using gas or propane water heaters to serve multiple dwelling units and/or common areas shall:
  - A. Be located in a space that can accommodate a heat pump water heating system of equivalent capacity and performance; and
  - B. Have a condensate drain that is no more than 2 inches higher than the base of the installed water heater, and allows natural draining without pump assistance; and
  - C. Include designated raceways and reserved capacity on the main electrical panel and subpanels, if applicable, sufficient to power one or more heat pump hot water heaters of equivalent combined capacity and performance. Plans shall include calculations for equivalent capacity and performance, electrical power, conductors, raceway sizes and panel capacities.

(o) - (r): Subsections 150.0(o) – (r) are adopted without modification.

(s) Subsection 150.0(s) is added be numbered, entitled, and to read as follows:

**Clothes Drying and Cooking.** Buildings plumbed for natural gas or propane clothes drying or cooking equipment shall include the following components for each gas terminal or stub out:

1. Clothes Drying.
  - A. A dedicated 240-volt, 30-amp electrical receptacle that is connected to the electrical panel with conductors of adequate capacity, within 3 feet of the appliance and accessible with no obstructions. In addition, all of the following:
    - i. Both ends of the unused conductor shall be labeled with the word “For Future Electric Clothes Dryer” and be electrically isolated; and
    - ii. A double pole circuit breaker in the electrical panel labeled with the words “For Future Electric Clothes Dryer”.
2. Cooking Range
  - A. A dedicated 240-volt, 50-amp electrical receptacle that is connected to the electrical panel with conductors of adequate capacity, within 3 feet of the appliance and accessible with no obstructions. In addition, all of the following:

- i. Both ends of the unused conductor shall be labeled with the word "For Future Electric Range" and be electrically isolated; and
- ii. A double pole circuit breaker in the electrical panel labeled with the words "For Future Electric Range".

**24.12.510 Performance and Prescriptive Compliance Approaches for Low-Rise Residential Buildings (Energy Standards, Subch. 7 §150.1)**

Energy Standards, Subchapter 7, Section 150.1 is amended to read as follows:

- (a) Section (a) is adopted without modification
- (b) Performance Standards. Building performance is calculated using Commission-certified compliance software as specified by the Alternative Calculation Methods Approval Manual.
  1. Newly Constructed Buildings. The Energy Budget for newly constructed buildings is expressed in terms of the Energy Design Rating, which is based on TDV energy. The Energy Design Rating (EDR) has two components, the Energy Efficiency Design Rating, and the Solar Electric Generation and Demand Flexibility Design Rating. The Solar Electric Generation and Demand Flexibility Design Rating shall be subtracted from the Energy Efficiency Design Rating to determine the Total Energy Design Rating. The Proposed Building shall separately comply with the Energy Efficiency Design Rating and the Total Energy Design Rating.
    - A. An All-Electric Building complies with the performance standard if both the Total Energy Design Rating and the Energy Efficiency Design Rating for the Proposed Building are no greater than the corresponding Energy Design Ratings for the Standard Design Building.
    - B. A Mixed-Fuel Building complies with the performance standards if the Energy Efficiency Design Rating of the Proposed Building is no greater than the Energy Efficiency Design Rating for the Standard Design Building; and if the Total Energy Design Rating for the Proposed Building is at least 10 points less than the Total Energy Design Rating for the Standard Design Building.

EXCEPTION 1 to Section 150.1(b)1.B. If the Certificate of Compliance is prepared and signed by a Certified Energy Analyst and the Total Energy Design Rating of the Proposed Design is no greater than the Standard Design Building, the

Total Energy Rating of the Proposed Building required by Section 150.1(b)1.B may be reduced by 1.

EXCEPTION 2 to Section 150.1(b)1.B. Buildings with limited solar access are excepted if all of the following are true:

- a. The Total Energy Design Rating for the Proposed Building is no greater than the Standard Design Building; and
- b. A photovoltaic (PV) system(s) meeting the minimum qualification requirements as specified in Joint Appendix JA11 is installed on all available areas of 80 contiguous square feet or more with effective annual solar access. Effective annual solar access shall be 70 percent or greater of the output of an unshaded PV array on an annual basis, wherein shade is due to existing permanent natural or manmade barriers external to the dwelling, including but not limited to trees, hills, and adjacent structures; and
- c. The Energy Efficiency Energy Design Rating for the Proposed Building is at least 2 points less than the Total Energy Design Rating for the Standard Design Building for Single Family Residences and at least 1 point less than the Total Energy Design Rating for the Standard Design Building for Low-Rise Multifamily Buildings.

EXCEPTION to Section 150.1(b)1. A community shared solar electric generation system, or other renewable electric generation system, and/or community shared battery storage system, which provides dedicated power, utility energy reduction credits, or payments for energy bill reductions, to the permitted building and is approved by the Energy Commission as specified in Title 24, Part 1, Section 10-115, may offset part or all of the solar electric generation system Energy Design Rating required to comply with the Standards, as calculated according to methods established by the Commission in the Residential ACM Reference Manual.

2. Additions and Alterations to Existing Buildings. The Energy Budget for additions and alterations is expressed in terms of TDV energy. A building complies with the performance standards if the energy consumption



calculated for the Proposed Building is no greater than the energy budget calculated for the Standard Design Building.

3. Section (b)(3) is adopted without modification.
- (c) Prescriptive Standards/Component Package. Buildings that comply with the prescriptive standards shall be designed, constructed, and equipped to meet all of the requirements for the appropriate Climate Zone shown in TABLE 150.1-A or B. In TABLE 150.1-A and TABLE 150.1-B, a NA (not allowed) means that feature is not permitted in a particular Climate Zone and a NR (no requirement) means that there is no prescriptive requirement for that feature in a particular Climate Zone as well as all of the requirements of Section 150.1(c)15 and 16, whichever are more stringent. Installed components shall meet the following requirements:
1. – 14. Subsections 150.1(c)(1) – (14) are adopted without modification.
  15. Additional Prescriptive Requirements for Single Family buildings.
    - A. Duct System Sealing and Leakage Testing. The duct systems shall exceed the minimum mandatory requirements of Section 150.0(m)11 A and B such that the total duct system leakage shall not exceed 2 percent of the nominal system air handler air flow.
    - B. Compact Hot Water. The hot water distribution system shall be designed and installed to meet minimum requirements for the basic compact hot water distribution credit according to the procedures outlined in the 2019 Reference Appendices RA4.4.6.
    - C. Ducted Central Forced Air Heating Systems. Central Fan Integrated Ventilation Systems. The duct distribution system shall be designed reduce external static pressure to meet a maximum fan efficacy equal to:

Gas Furnaces: 0.35 Watts per cfm

Heat Pumps: 0.45 Watts per cfm,

according to the procedures outlined in the 2019 Reference Appendices RA 3.3.
    - D. Energy Storage. A battery energy storage system with a minimum capacity equal to 5 kWh shall be installed. The system shall have automatic controls programmed to charge anytime PV generation is greater than the building load and discharge to the electric grid, beginning during the highest priced time of use hours of the day.

16. Additional Prescriptive Requirements for Multifamily buildings.
- A. Ducts in Conditioned Space. All ductwork shall be located entirely in conditioned space with ducts tested to have less than or equal to 25 cfm leakage to outside. Ductwork shall meet the requirements of Verified Low Leakage Ducts in Conditioned Space (VLLDCS) in the 2019 Reference Appendices RA3.1.4.3.8.
  - B. Roofing Products. Low-rise residential buildings with steep-sloped roofs shall have a minimum aged solar reflectance of 0.25.
  - C. Compact Hot Water. The hot water distribution system shall be designed and installed to meet minimum requirements for the basic compact hot water distribution credit according to the procedures outlined in the 2019 Reference Appendices RA4.4.6.
  - D. Central Fan Integrated Ventilation Systems. Central forced air system fans used to provide outside air, shall have an air-handling unit fan efficacy less than or equal to 0.35 W/CFM. The airflow rate and fan efficacy requirements in this section shall be confirmed through field verification and diagnostic testing in accordance with all applicable procedures specified in Reference Residential Appendix RA3.3. Central Fan Integrated Ventilation Systems shall be certified to the Energy Commission as RA3.7.4.2.
  - E. Solar photovoltaic. A PV system meeting the minimum qualification requirements as specified in Joint Appendix JA11 sized to offset 100%, or the maximum amount permitted by the utility provider, of the estimated site electricity load shall be installed. The plans shall include calculations for the electricity load and PV production.
  - F. Energy Storage. A battery energy storage system with a capacity equivalent to the PV system shall be installed. The system shall have automatic controls programmed to charge anytime PV generation is greater than the building load and discharge to the electric grid, beginning during the highest priced time of use hours of the day.

Tables 150.1-C, 150.1-A and 150.1-B and associated footnotes are adopted without modification

SECTION 17. This Ordinance shall become effective on January 1, 2020.

RD:CDW:CER  
4/7/2020

PASSED FOR PUBLICATION of title this \_\_\_\_\_ day of \_\_\_\_\_, 2019, by the following vote:

AYES:

NOES:

ABSENT:

DISQUALIFIED:

---

SAM LICCARDO  
Mayor

ATTEST:

---

TONI J. TABER, CMC  
City Clerk